


The HeatNet™ bridge is an OEM product called a ProtoCessor manufactured by FieldServer. The bridge comes pre-configured to correctly map the native Modbus registers to the appropriate protocol (BACnet, LonWorks, etc.). Every control network requires that each device have a unique address (IP, MAC, BACnet Node ID, etc.). The network is usually designed by a controls contractor and thus, we have no way of knowing the device addressing scheme being used. For this reason, it may be necessary to program the device in the field. The steps required are outline below.

This document assumes that you have a standalone (not connected to a network) computer (Desktop or Laptop) with an Ethernet network card. You will also need an Ethernet cable, the *RUIPING* utility, and the *RUINET* utility. The *RUIPING* and *RUINET* applications can be downloaded from the Literature Library on the HeatNet™ product website (Hydrotherm, RBI, etc), or directly from the ProtoCessor web site ([www.protocessor.com](http://www.protocessor.com)).

The ProtoCessor is shipped with a default IP address 192.168.1.24. The subnet mask is 255.255.255.0. You need to configure your computer so that it is on the same IP network as the ProtoCessor. The required steps are outlined in the following sections for Microsoft Windows 2000 and Windows XP. If you have already changed the IP Address and/or Subnet Mask, you will need to use the appropriate values. If you have forgotten, misplaced, or lost the correct IP Address and Subnet Mask, please consult the “Finding a Lost HeatNet™ Bridge” technical bulletin.


## ***Windows 2000***

Open the “*Windows Control Panel*” (Start->Settings->Control Panel) and double click “*Network and Dial-up Connections*” as shown in Figure 1 to open up the “*Network and Dial-up Connections*” window.




**Figure 1. Windows 2000 - Control Panel**

Right click on *“Local Area Connection”* and choose properties as shown in Figure 2 to open the *“Local Area Connection Properties”* dialog.




**Figure 2. Windows 2000 - Network Connections**

Select *“Internet Protocol (TCP/IP)”* and click the *“Properties”* button as shown in Figure 3 to open the *“Internet Protocol (TCP/IP) Properties”* dialog.



**Figure 3. Windows 2000 - Connection Properties**

Write down the current settings so that they can be restored when you are no longer connected to the ProtoCessor. Choose *“Use the following IP address”*, set the *“IP Address”* to 192.168.1.99, and set the *“Subnet Mask”* to 255.255.255.0 as shown in Figure 4. Click the *“OK”* button to save your changes.



**Figure 4. Windows 2000 - TCP/IP Properties**

Close all remaining dialogs and windows that were opened following the instructions in this section. Proceed to the *“Connecting the ProtoCessor”* section below.

## Windows XP

Open the “*Windows Control Panel*” (Start->Control Panel) and double click “*Network and Dial-up Connections*” as shown in Figure 5. to open up the “*Network Connections*” window.






Figure 5. Windows XP - Control Panel

Right click on “*Local Area Connection*” and choose properties as shown in Figure 6 to open the “*Local Area Connection Properties*” dialog.



**Figure 6. Windows XP - Network Connections**

Select “Internet Protocol (TCP/IP)” and click the “Properties” button as shown in Figure 7 to open the “Internet Protocol (TCP/IP) Properties” dialog.



**Figure 7. Windows XP - Connection Properties**

Write down the current settings so that they can be restored when you are no longer connected to the ProtoCessor. Choose *“Use the following IP address”*, set the *“IP Address”* to 192.168.1.99, and set the *“Subnet Mask”* to 255.255.255.0 as shown in Figure 8. Click the *“OK”* button to save your changes.




Figure 8. Windows XP - Internet Protocol Properties

## Connecting the ProtoCessor

Connect your computer directly to the ProtoCessor using an Ethernet cross-over cable, power up the ProtoCessor (apply power to the HeatNet™ product) and run the *Ruinet.exe* application. You should see the bridge responding as shown in Figure 9. Please note that the bridge name may be different on your product. If the bridge is not responding, as shown in Figure 10 there are several possibilities:

- 1) The Microsoft Windows (or another OEM) Firewall is preventing communications with the bridge. Disable any firewalls and try again.
- 2) The IP network settings on your computer were not correctly set. Please double check the settings outlined in the preceding sections to verify that they are set correctly.
- 3) The computer has multiple network cards and you have not configured or are not plugged into the correct port.
- 4) You are using a standard patch (straight through) Ethernet cable. You **must** use a cross-over cable.
- 5) The IP network settings (IP Address/Subnet) on the bridge have been changed from the default settings. Consult the "Finding a Lost HeatNet™ Bridge" technical bulletin.
- 6) The bridge is not powered or is defective. Please check for power, flashing lights, etc.

```
C:\Protocessor\ruiping.exe
=====
BRIDGE NAME                IP Address          S/W VERSION
=====
KNSX-LonWorks TP/FT v2.00  192.168.1.24       B?U5.10b <B>, PCC4002:U1.00a <A>
=====
BRIDGE NAME                IP Address          S/W VERSION
=====
KNSX-LonWorks TP/FT v2.00  192.168.1.24       B?U5.10b <B>, PCC4002:U1.00a <A>
=====
BRIDGE NAME                IP Address          S/W VERSION
=====
KNSX-LonWorks TP/FT v2.00  192.168.1.24       B?U5.10b <B>, PCC4002:U1.00a <A>
=====
BRIDGE NAME                IP Address          S/W VERSION
=====
KNSX-LonWorks TP/FT v2.00  192.168.1.24       B?U5.10b <B>, PCC4002:U1.00a <A>
=====
```

Figure 9. Ruiping - ProtoCessor Responding




Figure 10. Ruiping - ProtoCessor not Responding

If the bridge is responding, close the FieldServer *Ruiping* application and run the FieldServer *Ruinet* application as shown in Figure 11. Because you are plugged directly into the bridge there can only be one bridge on your network. The application may automatically switch to the “Main Menu Screen” as shown in Figure 12. If not, press “1”. You are now ready to monitor and/or configure the bridge. Please consult our technical bulletins (or the Field Server documentation) for configuring the most common settings.




Figure 11. Ruinet - Field Server List Screen




Figure 12. Ruinet - Main Menu Screen