


CODE OPTIONS

CSD-1	UTC Lockout/Reset Control Manual Reset LWCO
Kentucky (Water Htr Only)	200° F Maximum Operating Control and High Limit

NOTE: Dimensions are approximate and should not be used to "rough-in" equipment.

* Add circulator amps.

**For incoming gas pressures lower than 6" W.C. natural or 11" W.C. propane, consult factory.



RSUB-24-C

A.G.A. CERTIFIED RATINGS & CAPACITIES

Fuel Type	Natural/Propane Gas	Boiler FLA	16.33*
Input BTU/hr.	2,299,920 / 674 kW	Min. Gas Pressure Required	6" W.C.**
Output BTU/hr.	1,885,934 / 553 kW	Max. Gas Pressure Allowed	14" W.C.
Electrical Requirements	120VAC/ 1 ph/ 60 hz/ 17 amp	Operating Weight	1185 lbs. / 538 kg.

BOILER TRIM & CONTROLS

Main Gas Valve	Honeywell V8944B 2"	Pilot Valve	Honeywell VR8205Q
Firing Valve	Honeywell B200T1066 2"	Air Switch	Cleveland RSS-495
Safety Valve	Honeywell V48A 2"	Blower Motor	(2) 1/4 hp (1) 1/5 hp - FLA 13.2
Ignition Control	UTC 1003-61A	Relief Valve - LW	3/4" x 3/4" set @ 125 psi
Operating Control (LB/LW)	Jumo	Relief Valve - LB	1" x 1 1/4" set @ 50 psi
High Limit (LB/LW)	Jumo	Flow Switch	ITT FS4-3

A.S.M.E.

ASME Sect IV Htg Surface	202 Sq. Ft. / 18.77 Sq. M.	Design Data	Max. 160 psig & 250° F
---------------------------------	----------------------------	--------------------	------------------------

TEMPERATURE RISE / PRESSURE DROP

30° F / 16.7° C				35° F / 19.4° C			
Flow Rate		Pressure Drop		Flow Rate		Pressure Drop	
GPM	L/s	Ft	kPa	GPM	L/s	Ft	kPa
125.7*	7.9	12.45	36.7	107.8	6.8	9.36	27.6

*Flow exceeds recommended maximum use a greater temperature rise or consult manufacturer. Cupro-Nickel heat exchanger should be considered.

RECOVERY CAPACITY

40°F	22° C	60°F	33° C	80°F	44° C	100°F	56° C	120°F	67° C	140°F	78° C
5660	21426	3773	14284	2830	10713	2264	8570	1887	7142	1617	6122

REP FIRM _____
 SUBMITTED BY _____
 JOB NAME _____
 ARCHITECT _____
 ENGINEER _____
 CONTRACTOR _____
 DATE _____

LCD 2300

Category I or Category III Appliance

(See Installation and Operation Manual for venting information)



® A Division of Mestek, Inc.
 Westfield, MA 01085
 (413) 568-9571